

Device Details

Device Type : Battery NFC CO Alarm - FA3328
Device Location :
Firmware : 01.02
Date Of Manufacture : 30/05/2022

Present 30-Days Rolling Average

CO(ppm) : 0
Temperature C : 22
Humidity : 57

Previous 30-Days Rolling Average

CO(ppm) Minimum : 0
CO(ppm) Maximum : 110
CO(ppm) Average : 0
Temperature C Minimum : 0
Temperature C Maximum : 27
Temperature C Average : 0
Humidity Minimum : 0
Humidity Maximum : 74
Humidity Average : 0

Battery(1st Readings)

Voltage Level(V) : 3.037
Impedance Level(mV) : 9

Others

Number of Alarm : 1
Total Number of Alarm Minutes : 2
Number of Faults : 15

Number of Self Tests : 7

Number of On/Off Base : 9

Compliance Report & Maintenance Questions

Alarm Output : Pass

LED Sequence : Pass

Is The Device :

Installed correctly : Yes

In an area clear of furniture : Yes

In good condition : Yes

In need of replacement : No

Additional Information :

The automated report has been generated by on FA3328 NFC CO Alarm using NFC SYNC-IT TM Technology on 13/12/22 03:25:57

For more information on any data provided in this report please visit www.fireangel.co.uk/datareport