

Device Details

Device Type : Battery NFC CO Alarm - FA3328

Device Location :

Firmware : 01.02

Date Of Manufacture : 30/05/2022

Present 30-Days Rolling Average

CO(ppm) : 0

Temperature C : 22

Humidity : 57

Previous 30-Days Rolling Average

CO(ppm) Minimum : 0

CO(ppm) Maximum : 110

CO(ppm) Average : 0

Temperature C Minimum : 0

Temperature C Maximum : 27

Temperature C Average : 0

Humidity Minimum : 0

Humidity Maximum : 74

Humidity Average : 0

Battery(1st Readings)

Voltage Level(V) : 3.037

Impedance Level(mV) : 9

Others

Number of Alarm : 1

Total Number of Alarm Minutes : 2

Number of Faults : 16

Number of Self Tests : 7

Number of On/Off Base : 9

The automated report has been generated by on FA3328 NFC CO Alarm using NFC SYNC-IT TM Technology on 13/12/22 03:32:36

For more information on any data provided in this report please visit www.fireangel.co.uk/datareport